

To
 TNO - WP3.5
 Niels Jansen
 Milou Derks

From
 Boskalis Subsea Cables
 Ebo de Vries

Copy
 Tim van Keulen

Date
 Original: 28 November 2019
 Revision: 6 March 2020

Reference
 T39491 TNO

Page
 1 | 5

MEMO

NSE3 Powergrid - Estimation and assumptions - PUBLIC

INTRO

Boskalis Subsea Cables (BSC) joined the North Sea Energy consortium for a few years now and brought in their knowledge about offshore energy transportation by cables. BSC has made a preliminary design and non-binding cost estimation of the powergrid scenario based on available data. It concerns the Scenario I: Expanding and using the grid for electrification of high potential platforms.

This memo contains a budgetary proposal. Our proposal is only for the use of assessing the business case of the current powergrid scenario. This proposal based on a cable set up from IJmuiden Ver to a powergrid connection which starts at K14-FA.



Revision history		
Revision	Section	Change
1	3.0 Cable Design	Removed Connection K14 - K18-G from original scope.
1	4.0 Cost Estimation	Removed Connection K14 - K18-G from original scope.

1. MAIN ASSUMPTIONS AND PROVISIONS

General

- This proposal is based on the execution with our own vessels and burial spreads. Vessel costs are notoriously variable depending on their availability and the time of year. Also it is based on the current offshore operations market situation.
- This proposal is based on an uninterrupted installation period (24/7) of the whole powergrid in one campaign, as well as an uninterrupted access to all platforms in the project area.
- At this tender stage, Boskalis assumed Rotterdam as homeport for mobilization/demobilization of the vessels and other spreads. If the cable has to be loaded in a different port this might have consequences for the sailing durations and therefore to planning and price.
- Based on current prices of raw materials (e.g. steel and copper).
- Current fuel rates in Euro per Mt.
- No additional information related to the project area location and cable routes has been taken into account (e.g. water depth, geological and geotechnical conditions, location of J tubes, pull-in arrangements).
- No data available of the seabed around the platforms (e.g. scour protection, existing infrastructure)
- No view on interactions with existing pipelines or cables.
- Contractor has not allowed for any permitting or arranging any licenses and/or crossing agreements.
- CAR insurance is not included in our price and will normally be arranged by the Client.
- No allowance has been made for measures to be taken in case contaminated soil, unexploded ordnance, ammunition, wrecks or chemical waste are encountered during the works. It is assumed that the Employer will perform any removal work as may be necessary to avoid any risk to the installation equipment or cable, and prevent project delay wherever possible. ALARP certificate must be available and handed over to Boskalis prior the start of the works. In our offer, we have excluded UXO survey including reporting and approach and identification.
- This proposal does not include any delay due to weather limitations.
- It is assumed that employer will arrange for the management of interfaces between all parties involved.

Cable Route

- The needed kilometers are calculated based on a pathway in a straight line.
- Client shall be responsible for liaising with the owners of cables and pipelines to be crossed along the route, verifying the status of the cable/pipeline (i.e. in or out of service) and, where necessary, arranging for crossing agreements or permissions to remove cables taken out of service from the route.

Cable Design

- The scenario will assume one cable per connection which means there is no redundancy.
- Assumptions on cable type based on standardization program of Tennets offshore grid.
- Cable design is attached to appendix of this memo.

Soils & burial performance:

- Boskalis has assumed good jetable soils (i.e. medium dense sands) and a burial depth of 1.0m top of cable. No allowance has been made for pre-sweeping of sand waves.

Platform

- Assumption that a J-tube is present at platforms.
- It is assumed that J-tubes on the foundations will have only one bend, at the bottom, and that the bell mouth exit will approximately be 2m from the seabed/scour protection, with an exit angle of 45 degrees.

- Substations usually include medium and or high voltage transformers, switch gears and other electrical infrastructure. The electrical system hardware on the platform is excluded. Costs of termination is based on connection to available switch gear on platform.
- Sufficient space is available at the platform to create a safe working area for our personnel as well as a for easy routing of the cables in the platform structure. A straight pull-in over the J-tube is assumed to be possible and strongpoints are available at the platform. A maximum of 5 meter cable routing towards the termination point of cable and fiber optic is assumed.

2. SCOPE OF WORK

Pre-Survey and UXO survey	Excluded
PLGR – Pre Lay Grepnel Run	Included
Pre Lay Survey	Included
Post Lay Survey	Included
Boulder Clearance	Excluded
Pre Trenching	Excluded
Cable Storage	Excluded
Cable Transport	Included
Dredging	Excluded
Cable Lay	Included
Cable Lay & Burial	Included
Post Lay Cable Protection	Excluded
Cable Crossings	Included
Offshore Cable Joints	Included
Pull in at Offshore Sub Platform	Included
Termination and Testing	Included
Support Vessels	Included

3. CABLE DESIGN

The cable design is based on the supplied electrification scenario. The demand of every platform is taken into account. Based on this the total power is calculated per connection, to come to a powergrid scenario. Our proposal is to use two types of cables for this power grid. The voltage has been set on 66Kv, which is mainly based on the standardization program of Tennet's offshore grid. In this case there is no additional gear needed such as transformers or switch gears to lower the voltage. Lowering this voltage does not have any financial or technological benefits.

The connection in between platforms will be executed with an 150mm³ cable with aluminum cores (CSA1). The total power demand of the cable between Ijmuiden Ver and K14-FA exceeds the maximum power of CSA1. For this connection a cable is needed with a larger cross section. This cable (CSA2) is an 630mm³ cable with copper core elements.

The total demand per platform, as well as the total power per connection is shown in the table below. Also the total power which is transported per cable is shown.

Case 1: Connection to Ijmuiden Ver						Scenario 1: single circuit 630-Cu to OSS			
From	To	Req. power at platform [MW]	Req. power in cable [MW]	Line current in Cable [A]	Estimated CSA [mm ²]	Length [km]	CSA-1 150-Al	CSA-2 1x630-Cu	Joints
J6-A-Markham	K01-A	14,7	14,7	135	150-Al	9,1	9,1		
K01-A	K04-A	2,4	17,1	157	150-Al	18,4	18,4		1,0
K04-A	K05-A	4,2	21,3	196	150-Al	6,3	6,3		
K05-A	K05-B	6,2	27,5	253	150-Al	6,3	6,3		
K05-B	K14-FA	2,8	30,4	280	150-Al	51,2	51,2		4,0
L09-FF	L15-FA	12,1	12,1	111	150-AL	32,9	32,9		
L15-FA	L10-A	3,1	15,2	140	150-AL	42,7	42,7		
L05-FA	L10-A	2,7	2,7	25	150-AL	46,4	46,4		4,0
L10-A	K14-FA	13,2	31,1	286	150-AL	41,1	41,1		3,0
K14-FA	Ten Ijmuiden Ver Beta	27,2	88,7	817	630-CU	36,9		36,9	4,0
Total Kilometers						291,4	254,5	36,9	16,0

Technical Limitations

There are some technical limitations in the maximum cable lengths of 66kv cables. Currently a maximum distance of 30km is taken into account due to the loss of power. Three cables are expanding this maximum distance (shaded in yellow). Currently there are technical developments to extend this range, but probably a new cable design is needed where the voltage will increase to 132Kv. This has a big influence on the total price, mainly for the additional electronic gear. This gear will both increase in costs as in the dimensions.

4. COST ESTIMATION

Scenario I: Expanding and using the grid for electrification of high potential platforms		
		Estimation
1	PROJECT MANAGEMENT AND ENGINEERING	
2	PRE-INSTALLATION SURVEY & PLGR	
3	CABLE CROSSINGS MATRASS INSTALLATION	(5 pcs/crossing x 3 crossings)
4	MOBILISATION/DEMOBILISATION CABLE INSTALLATION	
5	LOAD OUT OF EXPORT CABLE	
6	TRANSIT FROM MOB PORT TO CABLE LOADING LOCATION	
7	CABLE LAYING & PULL-IN AT PLATFORMS	
8	OFFSHORE CABLE JOINTS	
8	CABLE BURIAL (POST LAY)	
9	SUPPLY & INSTALL CPS	
10	TERMINATION & TESTING WORKS	
11	SUPPORT VESSELS	
Total Sum Operations		€ 92.840.500

Cable Supply		
CSA1	3x150mm ³ Al 66kV	
CSA2	3x630mm ³ Cu 66kV	
Joints	18pc	
Additional Accessoires	10% of cable cost	
Total Sum Operations		€ 49.582.951

Total		€ 142.423.451
Cost per km	292	€ 487.752

- Transportation of the cable from manufacturer to Rotterdam is not taken into account. This amount can go up from one to five million, which depends on the location of the manufacturer. All manufactures are based in Europe. In distance this can go from Germany to the south of Greece.

Information contained in this document is of a confidential nature. No part of this document may be reproduced in any form, by print, photo print, microfilm or any other means without prior written permission from BOSKALIS SUBSEA CABLES.